



UAB "Megrame" Medis, Kirtimu 37A, Vilnius
10

CE DECLARATION OF CONFORMITY

LST EN 14351-1:2006

IV-78

Folding doors and windows, 321;330;431 up to 761; 770 or 743 opening types,
for use in residential or commercial areas.

(This profile is available in MIRA CLASIC aluminium cladding)

Resistance to wind load	Test pressure Frame camber	Class 2 Class C	*(8.20.15)
Water tightness	Pressure Pa Water tightness	200 5A	*(8.20.15)
Inflammability		SN	
Air permeability		4 klasė	*(8.20.15)
Glass unit tested	Total thickness of glass unit Structure of glass unit	Not indicated	
Airborne sound insulation index R_w (C;Ctr) dB		SN	
Heat transfer coefficient		SN (U-value calculated according to LST EN ISO 10077-1 standard)	
Product reliability	Number of cycles Reliability Class	20 000 Class 3	*(8.20.15)

SN – feature not indicated

* Data from GU test protocols for CE marking: GU ITT No.08/05-A148-Z3 (GU data summary table No. in CE file)